

Environmental Health, Safety and Risk Management Facilities and Fire Safety Program Fire and Life Safety Inspection

Building:	
-----------	--

1. Occupant Issues	3. Fire Protection Systems (EHSRM)						
a. Egress is unobstructed (minimum 42 inches)	a. Fire Panel is accessible.						
b. Pull stations are unobstructed	b. Fire Alarm System inspected within the last 12 months.						
c. Appropriate clearance to the ceiling (18/24 inches). Sprinkler heads are unobstructed.	c. Fire Alarm system components (panel, detectors, pull stations, audible, visuals) are functioning properly.						
d. Electrical panels accessible	d. Wet sprinkler System inspected within the last 12 months.						
e. Exit doors unlocked	e. Wet sprinkler system components are in in good working order.						
f. No storage of materials in the stairwell	f. Dry suppression system has been inspected within the last 6 months.						
g. Door coverings do not exceed 50% of the door area. Wall coverings do not exceed 20% of the aggregate wall area.	g. Dry suppression system components are in in good working order.						
h. Flammable and combustible liquids stored properly	h. Fire Extinguishers have been visually inspected monthly and Maintained annually by an approved contractor.						
i. No visible circuit overloading	i. Exit signs illuminated						
j. No use of extension cords as permanent wiring.	j. Emergency lighting and functioning.						
k. No damage to electrical outlets and cover plates are in place.	k. Evacuation signs present and unobstructed.						
l. No open flames (or evidence of) present							
m. General housekeeping acceptable							
n. Area free of excessive combustibles							
o. Doors open easily, self-closing doors operable	4. Facilities Issues						
2. Fire Evacuation Procedures	Electrical panels labeled, clearance maintained						
a. Exit drills conducted regularly (Indicate date of last drill)	Knockouts are present						
b. Occupants familiar with drill procedure and location of fire							
extinguishers	Electrical cover plates present						
c. Evacuation training provided on an annual basis.	Ceiling tiles in place						

Non-Compliant Items

Item	Comments

This ren	art outl	ines item	s that a	re non	-compliant with	local, state, federal	rules r	egulations	and	hest work nr	actices ne	rtaining to	occun	ational
						Non-compliant		_				_		days.
EHSRM	Repres	sentative:				Signatui	re:							